

25 October 2024

(24-7584)

Page: 1/2

Committee on Technical Barriers to Trade

Original: Spanish

NOTIFICATION

Corrigendum¹

The following communication, dated 24 October 2024, is being circulated at the request of the delegation of Honduras.

Honduran Technical Regulation (RTH) No. 29.04.04.24: Energy efficiency. Three-phase squirrel-cage AC induction motors, with nominal power of between 0.746 and 373 kW. Limits, test method and labelling.

Paragraphs 6 and 11 of document G/TBT/N/HND/104 of 21 October 2024 should read as follows:

6. Description of content: This Honduran Technical Regulation (RTH) establishes the relevant nominal and minimum efficiency values, the efficiency testing method, the approval criteria, and the minimum amount of specifications information to be included on the nameplates of three-phase squirrel-cage electric AC induction motors, open or enclosed, with nominal power of between 0.746 kW and 373 kW, imported into Honduras.

The following are covered by the notified Regulation:

- Three-phase squirrel-cage electric AC induction motors, with nominal power of between 0.746 kW and 373 kW
- Operation at three-phase AC voltages of 60 Hz, and nominal voltage of up to 600 V, singly or at any combination of voltages;
- Nominal frequency of 60 Hz or 50 Hz for operation at 60 Hz;
- Operation at a nominal frequency of 60 Hz, open or enclosed, mounted horizontally or vertically, and continuous-duty operation.

11. Texts available from: National enquiry point [X] or address, telephone and fax numbers and email and website addresses, if available, of other body:

- *Secretaría de Energía*, SEN (Ministry of Energy)

Edificio Altamira, salida a Valle de Ángeles, final del anillo periférico.

Email: danielbarralaga@sen.hn

Website: <http://www.sen.hn>

- *Secretaría de Desarrollo Económico*, SDE (Secretariat for Economic Development)

¹ In English and Spanish only.

Dirección General de Integración Económica y Política Comercial (Directorate-General of Economic Integration and Trade Policy)

Centro Cívico Gubernamental "José Cecilio del Valle".

Nivel 9, Torre 1

Tel.: (+504) 2242 8365

Email:

gabriela.salinas@sde.gob.hn;

gsalinas_sic@yahoo.com

Text available from: <https://sde.gob.hn/wp-content/uploads/2024/10/RTH-29.04.04.24-Eficiencia-energetica.-Motores-de-corriente-alterna.-Limites-metodo-de-prueba-y-etiquetado.pdf>
